

LATI Industria Termoplastici S.p.A.
Via F. Baracca, 7
21040 VEDANO OLONA (VA)
ITALIA

Rotthauer Str. 19
45879 Gelsenkirchen

Phone (0209) 9242-230
Fax (0209) 9242-222
E-Mail c.schell@hyg.de
Internet www.hyg.de

Reference: W-183761e-09-SI
Responsible: Mrs. Dr. Ch. Schell

Gelsenkirchen, 17.11.2009

TEST CERTIFICATE

Enhancement of Microbial Growth on Materials to Come into Contact with Drinking water Test pursuant to DVGW Technical Standard, November 2007

Client: LATI Industria Termoplastici S.p.A.
Via F. Baracca, 7
21040 VEDANO OLONA (VA)
ITALIA


Test material: LATIGLOSS 66 H2 G/50 BLACK:3352F2

Test method: Material test

According to test report **W-183761e-09-SI** from 17.11.2009, the afore mentioned material **LATIGLOSS 66 H2 G/50 BLACK:3352F2** is conform to the requirements for the use in the area of drinking water systems pursuant to DVGW Technical Standard W 270. The test results are itemized in the test report.

This test certificate shall become valid upon date of issue and shall expire on **17.11.2014** provided that conditions and requirements remain unaltered. Upon these conditions the validity may be extended on application up to another 5 years term.

Director of the Institute
On behalf


Dr. Ch. Schell
Department Water Hygiene and Environmental Microbiology



The test results and assessments refer exclusively to the examined test specimens and the existing regulations.
The validity of this document expires in case of modifications in the composition of the material or the processing conditions.
The present document may only be published and reproduced unabridged and unaltered.

This document is no DVGW-certification.



DAP-PL-2548.00